

CERTIFICATE

The company

VELUX A/S
Aadalsvej 99
2970 HOERSHOLM
DENMARK

with the production site in

Fertöd

hereby receives the confirmation that the product/s

Thermal solar systems

of the type


CLI U12 4000, TFF 300 0201

conforms to

DIN EN 12976-1:2006-04
DIN EN 12976-2:2006-04

Specific CEN KEYMARK Scheme Rules for Solar Thermal Products version 10.07 (Edition: 2009-02)

and is granted the licence to use the marks



in conjunction with the Registration No. below.

Registration No.: 011-7S445 A

This Certificate is valid until 2013-05-31.



DAP-ZE-2460.00

See annex for further information.

DIN CERTCO Gesellschaft für
Konformitätsbewertung mbH
Alboinstraße 56, 12103 Berlin



2009-12-18

Dipl.-Ing. Dipl.-Wi.-Ing. Sören Scholz
- Head of Certification Body -



Annex

to the Certificate with Registration No. 011-7S445 A, dated 2009-12-18

Technical data

see data sheet, part of the test report of 2008-05-28

Note(s):

- The freeze resistance test for the solar collector according to DIN EN 12975-2, clause 5.8 was not necessary.
According to the manufacturer's declaration, the certified solar collectors may be used in frost exposed areas only in combination with appropriate frost protection mixtures.
- The optional impact resistance test for the solar collector according to DIN EN 12975-2, clause 5.10 was not carried out.
- The proof of lightning protection according to DIN EN 12976-2, clause 5.5 was not subject to the test and shall be furnished separately.

Testing laboratory / Inspection body

IZES Institut für Zukunfts-
EnergieSysteme a.d. Hochschule
für Technik und Wirtschaft
Altenkesslerstraße 17
66115 Saarbrücken

Test report(s)

No. SYS08 05 dated 2008-05-28