



Certificate of constancy of performance

0402 - CPR - SC0927-14

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product

Natural smoke and heat exhaust ventilator

as specified in appendix to this certificate,
for use in smoke and heat control systems

Product name: GGL -K-- ----40, GGU -K-- ----40

produced by or for

Velux A/S
Ådalsvej 99
DK-2970 Hørsholm
Denmark

and produced in the manufacturing plants

A/S Østbirk Bygningsindustri, Ryvej 21, DK-8752 Østbirk, Denmark

SIG Sonnerborn, Am Arzbach 13, D-99869 Sonnerborn, Germany

Thyregod Bygningsindustri A/S, Nordre Ringvej 9, DK-7323 Give, Denmark

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in annex ZA of the standard

EN 12101-2:2003

under system 1 for the performances set out in this certificate are applied and that

the construction product fulfils all the prescribed requirements for these performances.

This certificate was first issued on 2015-03-12 and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared essential characteristics, do not change, and the construction product, and the manufacturing conditions in the plant are not modified significantly, unless suspended or withdrawn by the product certification body.

2015-03-12

SP Technical Research Institute of Sweden
Certification, Notified Body No. 0402

Lennart Aronsson
Product Certification Manager

Martin Tillander
Certification officer

SP Technical Research Institute of Sweden

Box 857, SE-501 15 Borås, Sweden
Phone: +46 10-516 50 00
E-mail, internet: info@sp.se, www.sp.se

4P00232-04 This is issue 1.
Swedish Notified Bodies are appointed by SWEDAC (the Swedish board for Accreditation and Conformity Assessment) under the terms of Swedish legislation. This certificate may not be reproduced other than in full, except with the prior written approval by SP.



Certificate of constancy of performance

0402 - CPR - SC0927-14 appendix

Natural smoke and heat exhaust ventilator, *GGL -K-- ----40, GGU -K-- ----40*

For use in smoke and heat control systems, in construction works.
Dual purpose ventilator, intended for comfort ventilation as well as smoke and heat exhaust ventilation under fire conditions.

The frame and sash of the ventilator is a normal roof window, the sash have up to 13 mm glass in total.

The flap has a pivot action, and is horizontally pivoted.

The ventilator can be equipped with or without wind deflectors.

The ventilator is for roof or wall mounting, and is tested with and without side wind.

Specifications:

Length and width (throat)	See values in size specifications table below
Installation angle	15° - 90°
Wind deflector (if equipped with this)	KFD 0000
Opening mechanism	Electrical chain motor and two gas jacks
Opening mechanism, supplier and type	Velux A/S, 3FM FK04 WW, 3FM FK06 WW, 3FM FK08 WW

Size Specifications

Size (GGL and GGU)			Aerodynamic free area A_a			
Size code	Height m	Width m	Roof mounted with KFD 0000 m ²	Roof mounted without KFD 0000 m ²	Wall mounted with KFD 0000 m ²	Wall mounted without KFD 0000 m ²
MK04	0.90	0.70	0.33	0.19	0.41	0.41
MK06	1.10	0.70	0.43	0.29	0.51	0.52
MK08	1.32	0.70	0.55	0.43	0.61	0.63
PK04	0.90	0.86	0.39	0.20	0.51	0.52
PK06	1.10	0.86	0.49	0.30	0.61	0.62
PK08	1.32	0.86	0.63	0.46	0.70	0.70
SK04	0.90	1.06	0.46	0.19	0.61	0.62
SK06	1.10	1.06	0.55	0.28	0.73	0.72
SK08	1.32	1.06	0.70	0.44	0.90	0.88
UK04	0.90	1.26	0.51	0.16	0.70	0.70
UK06	1.10	1.26	0.62	0.25	0.89	0.87
UK08	1.32	1.26	0.73	0.38	1.10	1.06

Performance/Classification:

Aerodynamic free area	See values in size specifications table above
Reliability	Re 1 000
Snow load	SL 1 000
Low ambient temperature	T(-15)
Wind load	WL 3 000
Resistance to heat	B 300
Reaction to fire	E